



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published:
Revised:

14-Apr-26

Public Notice ID: 2026-138
Page 1 of 2

Counterfeit Intertek Certificate of Compliance

Fire Alarm System Description Certificate

Notification Type:	Counterfeiting
Certification Type:	Not Intertek Certified

Notification

Intertek notifies consumers, retailers and distributors that we have been made aware of counterfeit Intertek certificates in the marketplace as identified below claiming products are Intertek Certified.

Company Identification

Albert's Electrical Services, Inc

Product Identification

A counterfeit document of a Fire Alarm System Description Certificate, Albert's Electrical Services, Inc., Issued 08/10/2025 Expires 08/10/2026, and counterfeit document shows a **RED** ETL Certification Mark with no control number. Certificate photos on Page 2.

Hazard Involved

Not Intertek Certified

What To Do

Use should be immediately discontinued and return to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers.



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published: April 14, 2026
Revised:

Public Notice ID: 2026-138
Page 2 of 2

Photos and Images / Photos et images

COUNTERFEIT

COUNTERFEIT

intertek
Total Quality. Assured.

Document ID: G105706880-9937N
Issued: 08/10/2025
Expires: 08/10/2026

ETL
Intertek

Fire Alarm System Description Certificate

Issuance of this Document indicates that the Alarm Service Company (and additional service centers, when applicable) is under independent Third Party Surveillance by Intertek in accordance with OSHA (29 CFR 1910.369(1)) and have been found to be in compliance with the applicable Nationally Recognized Standards (shown in Intertek's Listing Directory). They are eligible to reference the Intertek - ETL Certificate of Compliance in accordance with other NFPA listed Certified Alarm Systems. This Document is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party other than its Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to copy or distribute this Document. Any use of the Intertek name or one of its marks for the sale or advertisement of the service must first be approved, in writing, by Intertek. The observations listed in this Document are relevant only to the facility referred to.

Protected Property:
Royal Point Building 3
14615 Dunbar Drive
Miami, FL 33176

Alarm System Description:
System Type: Central Station
Area Covered: 3 story apartment building Fully sprinkled
Additional Coverage Notes: Partial
NFPA Standard: NFPA 72 (2019)
Coverage: Wet
Sprinkler System Type: Wet
Authority Having Jurisdiction Name: Miami Dade County
Responding Fire Department: Miami Dade County
Contract Date: 08/10/2025
Contract Term End Date: 08/10/2026

Alarm Service Company:
Alberts Electrical Service, Inc.
13751 SW 143 Court
Miami, FL 33186
Service Center No.: 1

Alarm System Items:

Control and Transmitter	Units	1	Stank SLE Max2/Napco/
Control and Transmitter	Units	4	BPS10/Kidde/
Annunciator	Units	1	RLCD/Kidde/
Full Station	12	MPSR1-640/Kidde/	
Horn Strobe	8	EG4VWF/Kidde/	
Bell	1	439D-10AW-R/Kidde/	
Horn Strobe	18	WGAVWF/Kidde/	
Waterflow Switches	3	BY OTHERS/	
Sprinkler Valve Supervisory Switches	3	BY OTHERS/	
Surge Protection	2	DTK-HW120/DIT/TK/	
Strobe Protection	2	DTK-2MHP24B/DIT/TK/	
Strobes	14	EG4VWF/Kidde/	
Horns	80	GAJ-WN-HK/Kidde/	
Integrated System Component - Module	3	GSA-CT2K/Kidde/ FLOW AND TAMPERS	
Integrated System Component - Module	1	GSA-CR/Kidde/	
Integrated System Component - Module	2	GSA-M/Kidde/	
Smoke Detectors	2	KI-OSD/Kidde/	

Monitoring:
Arco Central Station / 3905 Sw 110 Ave., Miami, FL 33165
Listed By: UL

Alarm Transmission:
Primary: LTE Cellular-Long-Term Evolution 3G/4G/5G
Secondary: LTE Cellular-Long-Term Evolution 3G/4G/5G
Additional: Public Telephone Network

Alarm Retransmission to Fire Department - Priority:
Primary: Public Telephone Network
Secondary: Public Telephone Network

Comments:

System Deviations:

NOTE: In accordance with the requirements of NFPA 72, this document shall be physically posted within 3 ft. of the fire alarm control unit.

Intertek Testing Services NA, Inc.
Attn: Certification Manager
545 E. Algonquin Road, Arlington Heights, IL 60005
(T) 847-439-5667 (F) 847-439-7320
www.intertek.com

intertek
Total Quality. Assured.

Document ID: G105706880-9937N
Issued: 08/10/2025
Expires: 08/10/2026

ETL
Intertek

Fire Alarm System Description Certificate

Issuance of this Document indicates that the Alarm Service Company (and additional service centers, when applicable) is under independent Third Party Surveillance by Intertek in accordance with OSHA (29 CFR 1910.369(1)) and have been found to be in compliance with the applicable Nationally Recognized Standards (shown in Intertek's Listing Directory). They are eligible to reference the Intertek - ETL Certificate of Compliance in accordance with other NFPA listed Certified Alarm Systems. This Document is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party other than its Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to copy or distribute this Document. Any use of the Intertek name or one of its marks for the sale or advertisement of the service must first be approved, in writing, by Intertek. The observations listed in this Document are relevant only to the facility referred to.

Protected Property:
Royal Point Building 4
14686 Dunbar Drive
Miami, FL 33176

Alarm System Description:
System Type: Central Station
Area Covered: 3 story apartment building Fully sprinkled
Additional Coverage Notes: Partial
NFPA Standard: NFPA 72 (2019)
Coverage: Wet
Sprinkler System Type: Wet
Authority Having Jurisdiction Name: Miami Dade County
Responding Fire Department: Miami Dade County
Contract Date: 08/10/2025
Contract Term End Date: 08/10/2026

Alarm Service Company:
Alberts Electrical Service, Inc.
13751 SW 143 Court
Miami, FL 33186
Service Center No.: 1

Alarm System Items:

Control and Transmitter	Units	1	Stank SLE Max2/Napco/
Control and Transmitter	Units	4	BPS10/Kidde/
Annunciator	Units	1	RLCD/Kidde/
Full Station	21	MPSR1-640/Kidde/	
Horn Strobe	8	EG4VWF/Kidde/	
Bell	1	439D-10AW-R/Kidde/	
Horn Strobe	18	WGAVWF/Kidde/	
Waterflow Switches	3	BY OTHERS/	
Sprinkler Valve Supervisory Switches	3	BY OTHERS/	
Surge Protection	2	DTK-HW120/DIT/TK/	
Strobe Protection	2	DTK-2MHP24B/DIT/TK/	
Strobes	10	EG4VWF/Kidde/	
Horns	80	GAJ-WN-HK/Kidde/	
Integrated System Component - Module	3	GSA-CT2K/Kidde/ FLOW AND TAMPERS	
Integrated System Component - Module	1	GSA-CR/Kidde/	
Integrated System Component - Module	2	GSA-M/Kidde/	
Smoke Detectors	2	KI-OSD/Kidde/	

Monitoring:
Arco Central Station / 3905 Sw 110 Ave., Miami, FL 33165
Listed By: UL

Alarm Transmission:
Primary: LTE Cellular-Long-Term Evolution 3G/4G/5G
Secondary: LTE Cellular-Long-Term Evolution 3G/4G/5G
Additional: Public Telephone Network

Alarm Retransmission to Fire Department - Priority:
Primary: Public Telephone Network
Secondary: Public Telephone Network

Comments:

System Deviations:

NOTE: In accordance with the requirements of NFPA 72, this document shall be physically posted within 3 ft. of the fire alarm control unit.

Intertek Testing Services NA, Inc.
Attn: Certification Manager
545 E. Algonquin Road, Arlington Heights, IL 60005
(T) 847-439-5667 (F) 847-439-7320
www.intertek.com